

Model: **KD80U/KD88**

KOHLER POWER SYSTEMS

200-600 V

Diesel



Ratings Range

		KD80U 60 Hz	KD88 50 Hz
Standby:	kW	70-80	62-70
	kVA	88-100	77-88
Prime:	kW	64-73	56-64
	kVA	80-91	70-80

Standard Features

- D Kohler Co. provides one-source responsibility for the generating system and accessories.
- D The generator set and its components are prototype-tested, factory-built, and production-tested.
- D A one-year limited warranty covers all systems and components.
- D John Deere engine with 12-volt battery charging alternator.
- D Leroy Somer single-bearing alternator with insulation class H.
- D Unit-mounted radiator with 50_C (122_F) ambient air capability.
- D Skid and vibration isolators.
- D Subbase fuel tank, 180 L (48 gal.).
- D Dry type air filter.
- D Main line circuit breaker.
- D Microprocessor controller.
- D Battery, battery rack, and cables.
- D Industrial 9 dB(A) reduction exhaust silencer (loose).
- D Operation and installation literature.

Generator Set Ratings

Alternator	Voltage	Ph	Hz	Standby Rating		Prime Rating	
				kW/kVA	Amps	kW/kVA	Amps
	120/208	3	60	74/93	258	67/84	232
	127/220	3	60	78/98	257	71/89	233
	115/230	3	60	70/88	221	64/80	201
	120/240	3	60	74/93	224	67/84	201
	254/440	3	60	78/98	129	71/89	116
	277/480	3	60	80/100	120	73/91	110
	347/600	3	60	80/100	96	73/91	88
LSA432L8	115/200	3	50	70/88	254	64/80	231
	110/220	3	50	70/88	231	64/80	210
	127/220	3	50	62/77	202	56/70	184
	115/230	3	50	70/88	221	64/80	201
	120/240	3	50	70/88	212	64/80	192
	220/380	3	50	68/85	129	62/77	118
	230/400	3	50	70/88	127	64/80	115
	240/415	3	50	70/88	122	64/80	111



With Available Enclosure Accessory

RATINGS: All three-phase units are rated at 0.8 power factor. See TIB-109 for generator set derate tables. Obtain the technical information bulletin (TIB-101) on ratings guidelines for the complete ratings definitions.

PRP: Prime power is available for an unlimited number of annual operating hours in variable load applications in accordance with ISO-8528/1. A 10% overload capability is available for a period of 1 hour within a 12-hour period of operating in accordance with ISO-3046/1.

ESP: The emergency standby power rating is applicable for supplying emergency power in variable load applications in accordance with ISO-8528/1. Overload is not allowed. The generator set manufacturer reserves the right to change the design or specifications without notice and without any obligation or liability whatsoever.